



# 中国国家强制性产品认证证书



证书编号：2020322313003408

认证委托人名称： CMP PRODUCTS LTD  
 认证委托人地址： Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom  
 生产者名称： CMP PRODUCTS LTD  
 生产者地址： Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom  
 生产企业名称： CMP PRODUCTS LTD  
 生产企业地址： Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

产品名称： 电缆引入装置  
 系列、规格、型号： TC, TCCG  
 标准： GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、GB 12476.1-2013、GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求，特发此证。


发证日期：2020年11月24日      有效期至：2025年11月23日

首次发证日期：2020年11月24日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 [www.cnca.gov.cn](http://www.cnca.gov.cn) 查询



批准： 



## 上海仪器仪表自控系统检验测试所有限公司



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



**CERTIFICATE NO: 2020322313003408**

**APPLICANT:** **CMP PRODUCTS LTD**  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

**MANUFACTURER:** **CMP PRODUCTS LTD**  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

**FACTORY:** **CMP PRODUCTS LTD**  
**ADDRESS:** Unit 36 Nelson Way, Nelson Park East, Cramlington, Northumberland, NE23 1WH, United Kingdom

**PRODUCTNAME:** CABLE GLANDS

**SERIES,SPECIFICATION,MODEL:** TC, TCCG

**STANDARDS:** GB 3836.1-2010、GB 3836.2-2010、GB 3836.3-2010、GB 12476.1-2013、GB 12476.5-2013

This is to certify that the above mentioned product(s)complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

**Valid from:**November 24, 2020

**Valid until:** November 23, 2025

**Date of original certification:**November 24, 2020

**The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.**

This certificate is available through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



APPROVAL:

  
 \_\_\_\_\_  
 Guo AiHua



**Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.**

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0004148



# 中国国家强制性产品认证证书



证书编号: 2020322313003408

## 附件

产品名称: 电缆引入装置

型号规格: TC、TCCG

格兰/密封与电缆外径比例关系见下表:

规格型号	电缆外径尺寸范围 (mm)
20s	3.2-7.0
20*	6.5-14.0
25*	11.1-20.0
32*	17.0-26.3
40*	23.5-32.2
50s*	31.0-38.2
50	35.6-44.1
63s	41.5-50.1
63	47.2-56.0
75s	54.0-62.0
75	61.1-68.0
90	66.6-80.0
100	76.0-90.0
*可拆卸嵌件	

防爆标志: Ex e IIC Gb; Ex d IIC Gb; Ex tD A20 IP66。

电气参数: /

批准:



## 上海仪器仪表自控系统检验测试所有限公司